

Eckelmann

Release notes

Controller WRG 3010 E Firmware V1.4



Eckelmann

Eckelmann AG **Business Unit Refrigeration and Building Management Systems**

Berliner Straße 161
65205 Wiesbaden
Deutschland

Tel.: +49 611 7103-700

Fax: +49 611 7103-133

elds-support@eckelmann.de

www.eckelmann.de

Board of Directors: Dipl.-Ing. Peter Frankenbach (Speaker),
Dipl.-Wirtsch.-Ing. Philipp Eckelmann, Dr.-Ing. Marco Münchhof,

Chairman of the supervisory board: Hubertus G. Krossa

Registration court / registration number: District court Wiesbaden Germany, HRB 12636

Before commissioning and use, please check that this is the latest version of the document. With the publication of a new version of the documentation, all previous versions lose their validity.

Errors and technical modifications are expressly reserved.

The current operating manual and information such as data sheets, more detailed documentation and FAQs are available for you on-line in E°EDP (Eckelmann ° Electronic Documentation Platform) at **www.eckelmann.de/elds**



You reach all relevant documents for this component directly using the QR code.

All rights to any use whatever, utilisation, further development, forwarding and creation of copies remain with the Eckelmann AG company.

In particular, neither the contract partners of Eckelmann AG nor other users have the right to distribute or market the IT programs/program parts or modified or edited versions without express written permission. To some extent, names of products/goods or designations are protected for the respective manufacturer (registered trademarks etc.); in any case, no guarantee is assumed for their free availability/permission to use them. The information provided in the description is given independently of any existing patent protection or other third-party rights.

Eckelmann

Release notes

Controller WRG 3010 E



A firmware update is **only** to be carried out by trained staff or factory-side by the manufacturer!

The following is a summary of new functions of the current firmware.

New features compared to previous versions

Version 1.4

- Shifting the flow/return setpoint via the outdoor temperature
- Service area for manual override of analogue inputs and outputs
- Advanced troubleshooting support

Version 1.3

- Generation of the power signal with water circuit temperatures

Version 1.1

- Pt1000 calibration

Version 1.0

- Initial version
- Functions:
 - High temperature heat recovery
 - Low temperature heat recovery
 - High pressure adjustment in combination with the VS 3010 CT
 - Switching off the gas cooler fans in combination with the VS 3010 CT
 - Gas cooler bypass
 - Enable of an air heat pump
 - Air conditioning operation